

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

April 1, 2023

TITLE OF DOCUMENT (new title if applicable):

Instrumentation and Control for Boiler Plant, 23 09 11

DATE OF VERSION BEING SUPERSEDED (old):

March 1, 2022

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Instrumentation and Control for Boiler Plant, 23 09 11

SUMMARY OF CHANGES IN THIS VERSION:

1. Updated references and dates on standards.
2. Coordinated order of paragraphs with other sections in Division 23.
3. Corrected grammatical, punctuation and typographical errors both for corrections and for consistency with the other sections and divisions.
4. 1.5 A changed to reference Section 23 05 10 / 23 05 11 for consistency.

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

March 1, 2022

TITLE OF DOCUMENT:

Instrumentation and Control for Boiler Plant, 23 09 11

DATE OF VERSION BEING SUPERSEDED (old):

August 1, 2021

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Instrumentation and Control for Boiler Plant, 23 09 11

SUMMARY OF CHANGES IN THIS VERSION:

1. Remove recycling high pressure limit
2. Add high pressure limit with manual reset.
3. Add high-high pressure limit with manual reset.
4. Remove atomizing media flow switch and added a second pressure switch
5. Remove push button test for current relays and added an independent cabinet for the current relays.