

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

March 1, 2022

TITLE OF DOCUMENT:

Boiler Plant Mechanical Equipment, 23 50 11

DATE OF VERSION BEING SUPERSEDED (old):

April 1, 2020

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Boiler Plant Mechanical Equipment, 23 50 11

SUMMARY OF CHANGES IN THIS VERSION:

1. Remove DA overflow to condensate tank
2. DA must overflow to an open drain