



BIOLOGICAL SAFETY CABINET EXHAUST SYSTEM (CLASS II TYPE B1 OR B2)

#

NTS

DESIGNER'S NOTES:

1. COORDINATE SIZE AND TYPE OF BIOLOGICAL SAFETY CABINET (BSC) WITH THE ARCHITECTURAL EQUIPMENT DRAWINGS.
2. ESTABLISH EXHAUST REQUIREMENTS AND CHARACTERISTICS OF THE BSC BASED ON PROJECT PROGRAM AND VA HVAC DESIGN MANUAL.



Department of
Veterans Affairs

DETAIL TITLE / BIOLOGICAL SAFETY CABINET EXHAUST SYSTEM

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD115353-02.DWG