


(STEEL PIPE FOR STEAM OR WATER)

SCHEDULE FOR PIPING CROSSING A SEISMIC JOINT						
LOCATION	PIPE	DETAIL	DIMENSIONS INCHES [mm]			
			a	b	c	d
-	-	-	-	-	-	-
-	-	-	-	-	-	-

## PIPING CROSSING A SEISMIC JOINT DETAIL "D"



NTS

DESIGNER'S NOTE:

1. THIS CONFIGURATION SHOWN IN THIS DETAIL IS A SUGGESTED ARRANGEMENT, NOT MANDATED FOR USE IN AS IS CONDITION. THE REGISTERED PROFESSIONAL STRUCTURAL ENGINEER IN CHARGE OF THE PROJECT SHALL PROVIDE SEISMIC CALCULATIONS AND MODIFY THE CONFIGURATION AS NEEDED TO MAKE THE ARRANGEMENT PROJECT-SPECIFIC. THE MECHANICAL DESIGNER SHALL COMPLETE THE BLANK SCHEDULES BY INSERTING THE DISTANCES, TO BE CALCULATED AND FURNISHED BY PROVIDED BY THE REGISTERED PROFESSIONAL STRUCTURAL ENGINEER.



Department of  
Veterans Affairs

DETAIL TITLE / PIPING CROSSING A SEISMIC JOINT  
DETAIL "D"

SCALE :NONE

DATE ISSUED :DECEMBER 2008

CADD DETAIL NO. : SD230511-32.DWG