


NOTES:

1. ATTACH THRUST RESTRAINTS SYMMETRICALLY ON BOTH SIDES OF THE FAN DISCHARGE.
2. ADJUST RESTRAINT TO ALLOW 1/4" [6 mm] MOVEMENT OF FAN AT START AND STOP.



THRUST RESTRAINT FOR FANS

NTS

DESIGNER'S NOTE:

ON THE VIBRATION ISOLATION SCHEDULE OR UNDER THE TITLE OF THIS DETAIL DESIGNATE FANS REQUIRING RESTRAINT. THIS IS USUALLY SEPARATELY MOUNTED FAN SECTIONS FOR STATIC PRESSURE OVER 4" [100 mm] AND POSSIBLY FOR AXIAL FLOW FANS FOR STATIC PRESSURE OVER 4" [100 mm].



Department of
Veterans Affairs

DETAIL TITLE / THRUST RESTRAINT FOR FANS

SCALE :NONE

DATE ISSUED : DECEMBER 2008

CADD DETAIL NO. : SD230541-02.DWG