


CONTROL SYSTEM CONFIGURATION
 OPTION 1 -
 NEW BACNET ECC, UPGRADE EXISTING
 CONTROLS WITH NEW BACNET CONTROLS
 SYSTEM, INSTALL NEW BACNET
 COMMUNICATIONS NETWORK.

- NOTES:
1. REPLACE EXISTING ECC WITH NEW BACNET (B-AWS) ENGINEERING CONTROL CENTER.
 2. REPLACE ALL EXISTING CONTROLLERS WITH NEW BACNET CONTROLLERS.
 3. INSTALL NEW BACNET COMMUNICATION NETWORK.
 4. INSTALL MULTIPLE BUILDING CONTROLLERS (B-BC) AS REQUIRED.
 5. INSTALL NEW CONTROLLERS (B-AAC, B-ASC) AS REQUIRED.
 6. PROVIDE NEW PORTABLE OPERATORS TERMINAL.



BACNET SYSTEM ARCHITECTURE OPTION 1

NTS

DETAIL TITLE / BACNET SYSTEM ARCHITECTURE OPTION 1

Department of
Veterans Affairs



SCALE : NONE

DATE ISSUED: SEPTEMBER 2010

CAD DETAIL NO.: SD230923-11.DWG