


CONTROL SYSTEM CONFIGURATION
 OPTION 2 –
 NEW BACNET ECC, INSTALL NEW BACNET CONTROLS ON CURRENT PROJECT, PROVIDE BACNET GATEWAY FOR EXISTING CONTROL SYSTEM. INSTALL NEW BACNET COMMUNICATION NETWORK.

INSTALL NEW GATEWAY FOR COMMUNICATION WITH EXISTING CONTROL SYSTEM

EXISTING CONTROLLER PROTOCOL

NOTES:

1. REPLACE EXISTING ECC WITH NEW BACNET (B-AWS) ENGINEERING CONTROL CENTER (ECC).
2. EXISTING CONTROLLERS TO REMAIN.
3. INSTALL NEW BACNET GATEWAY WITH FULL COMMUNICATION TO EXISTING CONTROLLERS.
4. INSTALL NEW BACNET COMMUNICATION NETWORK.
5. INSTALL MULTIPLE BUILDING CONTROLLERS AS REQUIRED.
6. INSTALL NEW CONTROLLERS (B-AAC/B-ASC) AS REQUIRED.
7. PROVIDE NEW PORTABLE OPERATORS TERMINAL.



NTS

BACNET SYSTEM ARCHITECTURE OPTION 2

DETAIL TITLE / BACNET SYSTEM ARCHITECTURE OPTION 2

Department of
Veterans Affairs



SCALE : NONE

DATE ISSUED: SEPTEMBER 2010

CAD DETAIL NO.: SD230923-12.DWG