


NOTES:

1. ALL DRIP POINTS ON STEAM MAINS SHALL BE PROVIDED WITH A 300mm [12"] MINIMUM HIGH DRIP LEG FROM BOTTOM OF STEAM MAIN TO TRAP INLET. DRIP LEG SHALL HAVE 150mm [6"] SCALE POCKET BELOW TRAP INLET.
2. PROVIDE BYPASS PIPING.



INVERTED BUCKET STEAM TRAP ASSEMBLY

NTS



Department of
Veterans Affairs

DETAIL TITLE: INVERTED BUCKET STEAM TRAP ASSEMBLY

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD232213-02.DWG