



STORAGE TANK NO. 1 CHILLED WATER SCALE AND CORROSION INHIBITOR  
 STORAGE TANK NO. 2 TOWER BIOCIDES  
 STORAGE TANK NO. 3 TOWER SCALE AND CORROSION INHIBITOR  
 STORAGE TANK NO. 4 BROMINE FEEDER

# WATER TREATMENT SYSTEM - COOLING TOWER

# NTS

- DESIGNERS NOTES:
1. DESIGN WATER TREATMENT SYSTEM BASED ON THE AVAILABLE WATER SAMPLE ANALYSIS AND RECOMMENDATIONS OF THE WATER TREATMENT CONSULTANT.
  2. PROVIDE INTERFACE BETWEEN CHEMICAL FEED CONTROLLER AND ECC.
  3. CHILLED WATER WATER TREATMENT SYSTEM SHALL BE OPERATED MANUALLY.
  4. ADDITIONAL STORAGE TANKS AND FEED PUMPS MAY BE REQUIRED BASED ON THE OUTCOME OF THE WATER SAMPLE ANALYSIS.
  5. ENSURE CLOSE COORDINATION BETWEEN THE CONTRACT SPECIFICATIONS AND DETAILS.

DETAIL TITLE / WATER TREATMENT SYSTEM - COOLING TOWER

Department of Veterans Affairs



SCALE : NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD232500-03.DWG