


**NOTE:**

1. SECURE CURB CAP TO WOOD NAILING STRIP WITH 3/8" [10mm] CADMIUM PLATED LAG BOLTS NOT OVER 12" [300mm] ON CENTER.
2. SECURE ROOF CURB, DUCTWORK AND DAMPER TO ROOF WITH EXPANSION BOLTS (CONCRETE ROOF) OR RUST RESISTANT BOLTS (METAL DECK AND BAR JOIST ROOF).
3. RUN ELECTRICAL LINES THROUGH CLEARANCE HOLE PROVIDED IN GRAVITY DAMPER, THEN THROUGH VENTILATOR ELECTRICAL CONDUIT GUIDE.



## POWER ROOF VENTILATOR

NTS

**DESIGNERS NOTES:**

1. PROVIDE A MOTORIZED DAMPER, IF APPLICABLE.
2. PROVIDE DIRECT DRIVE FANS FOR LOCATIONS NOT EASILY ACCESSIBLE. AS ATTIC OR PIPE BASEMENT AND LESS THAN 2 HP.
3. MINIMUM CURB HEIGHT SHALL BE 12 INCHES [300 mm]. INCREASE HEIGHT, IF REQUIRED, TO OVERCOME SNOW DRIFT.



Department of  
Veterans Affairs

DETAIL TITLE / POWER ROOF VENTILATOR

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD233400-01.DWG