



NOTE:

1. THE BASINS SHALL BE INTERCONNECTED BY FLUMES. EACH CELL SHALL BE PROVIDED WITH ITS OWN SUMP AND ANTI-CAVITATION PLATE.

MULTIPLE CELL COOLING TOWER - PIPING CONNECTIONS

#

NTS

DESIGNERS NOTES:

1. IF TOWER IS INSTALLED MORE THAN 5 FT [1500 MM] ABOVE THE ROOF OR GRADE, PROVIDE A PLATFORM AROUND THE PERIMETER.
2. PROVIDE ACCESS FOR ALL ELEVATED VALVES AND CONTROL DEVICES AND TO EACH FAN MOTOR.
3. SEE HVAC DESIGN MANUAL.
4. COORDINATE WITH ELECTRICAL ON BASIN HEATER.



Department of Veterans Affairs

DETAIL TITLE / MULTIPLE CELL COOLING TOWER - PIPING CONNECTIONS

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.:

SD236500-01.DWG