


NOTES:

1. TO PREVENT ICING ON EXHAUST COIL MAINTAIN TEMPERATURE OF SOLUTION ENTERING EXHAUST AIR COIL $\geq 35^{\circ}$ F BY MODULATING 3 WAY VALVE.
2. DISCONTINUE HEAT RECOVERY IF OUTSIDE AIR TEMPERATURE \geq BETWEEN 60 TO 80° F (ADJUSTABLE)
3. FOR SYSTEMS WITH WINTER DESIGN CONDITIONS $\leq 32^{\circ}$ F, PROVIDE APPROPRIATE PROPYLENE GLYCOL SOLUTION.



RUN AROUND HEAT RECOVERY COIL DETAIL

NTS



Department of
Veterans Affairs

DETAIL TITLE / RUN AROUND ENERGY RECOVERY DETAIL

SCALE :NONE

DATE ISSUED: DECEMBER 2008

CAD DETAIL NO.: SD237200-01.DWG