


NOTES:

1. WHEN COIL IS INCLUDED IN CASING MOUNTED ON VIBRATION ISOLATORS THE FIRST 2 HANGERS FOR EACH PIPE SHALL BE SPRING & NEOPRENE TYPE. TYPE "H" FOR 100mm [4"] ϕ PIPE & SMALLER. TYPE "H-P" FOR 125mm [5"] ϕ PIPE & LARGER.
2. PIPING SHALL BE INSTALLED IN SUCH MANNER THAT IT WILL NOT BLOCK THE SWING OR USE OF ACCESS DOORS OR PANELS; NEITHER SHALL IT BLOCK THE SERVICING OF FILTERS, VALES, OR EQUIPMENT.
3. THE FLOW ELEMENT MAY BE INSTALLED IN THE SUPPLY PIPING IF THE REQUIRED MINIMUM UPSTREAM AND DOWNSTREAM DIMENSIONS CANNOT BE OBTAINED IN THE RETURN PIPING.



WATER COILS - PIPING CONNECTIONS

NTS



Department of
Veterans Affairs

DETAIL TITLE: WATER COILS - PIPING CONNECTIONS

SCALE :NONE

DATE ISSUED: 11/01/2017

CAD DETAIL NO.: SD238216-01.DWG