

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

June 1, 2015

TITLE OF DOCUMENT:

Manual Dry Standpipe Systems, 21 12 00

DATE OF VERSION BEING SUPERSEDED (old):

December 1, 2005

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Fire-Suppression Standpipes, 21 12 00

SUMMARY OF CHANGES IN THIS VERSION:

1. New specification section was written to address manual dry standpipes only.
2. Water supply is based on local fire engine providing providing water and pressure.
3. Stand-alone wet standpipes are not installed VA facilities unless they are installed as part of a combined sprinkler/standpipe system and therefore, wet standpipes were removed from the section.
4. Wet standpipes if required, are covered as a combined system in the Wet Pipe Sprinkler system section 21 13 13.