

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

September 1, 2020

## **TITLE OF DOCUMENT (new title if applicable):**

Fuel-Fired Domestic Water Heaters, 22 34 00

## **DATE OF VERSION BEING SUPERSEDED (old):**

September 1, 2015

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Fuel-Fired Domestic Water Heaters, 22 34 00

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. General grammatical changes
2. 1.2 – Updated Related Work Section and removed sections that were not referenced in the body of the specification.
3. 1.3 – Updated Applicable Publications
4. 1.5 – Added reference to 01 81 13, Sustainable Construction Requirements in section.
5. 1.6 – Replaced all text to comply with Section 220511.
6. Expanded Spec Writers Notes to explain some terminology used in the section.
7. 2.1.1 – Expanded requirements for drain valves. ASSE 1005 which specified drain valve requirements has been discontinued. Added verbiage intended to replace ASSE 1005 requirements.
8. 2.2.E.4 – Added spec writer note to ensure designer coordinates damper requirements with manufacturer and installation.
9. 2.2.I – Expanded requirements for drain valves. ASSE 1005 which specified drain valve requirements has been discontinued. Added verbiage intended to replace ASSE 1005 requirements.

10. 2.3.H – Expanded requirements for drain valves. ASSE 1005 which specified drain valve requirements has been discontinued. Added verbiage intended to replace ASSE 1005 requirements.
11. 2.4.I – Expanded requirements for drain valves. ASSE 1005 which specified drain valve requirements has been discontinued. Added verbiage intended to replace ASSE 1005 requirements.
12. 3.1.O. Added requirement to provide acid neutralization kits for condensing water heaters.